NVERTERS

Three Phase Inverters for the 277/480V Grid for North America

SE20KUS / SE30KUS / SE33.3KUS / SE40KUS



The best choice for SolarEdge enabled systems

- Specifically designed to work with power optimizers
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for superior efficiency (98.5%) and longer strings
- Built-in type 2 DC and AC Surge Protection, to better withstand lightning events
- Small, lightest in its class, and easy to install outdoors or indoors on provided bracket

- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12
- Built-in module-level monitoring with Ethernet, wireless or cellular communication for full system visibility
- Integrated Safety Switch
- UL1741 SA certified, for CPUC Rule 21 grid compliance



/ Three Phase Inverters for the 277/480V Grid(1) for North America

SE20KUS / SE30KUS / SE33.3KUS / SE40KUS

MODEL NUMBER	SE20KUS	SE30KUS	SE33.3KUS	SE40KUS		
APPLICABLE TO INVERTERS WITH PART NUMBER	SEXXK - SEXXK-USX8IXXXX					
OUTPUT					<u> </u>	
Rated AC Power Output	20000	30000	33300	40000	W	
Maximum apparent AC output power	20000	30000	33300	40000	VA	
AC Output Line Connections	4W + PE		3W + PE, 4W + PE			
AC Output Voltage Minimum-Nominal-Maximum ⁽²⁾ (L-N)	244 - 277 - 305				Vac	
AC Output Voltage Minimum-Nominal-Maximum ⁽²⁾ (L-L)	422.5 - 480 - 529				Vac	
AC Frequency Min-Nom-Max ⁽²⁾	59.3 - 60 - 60.5			Hz		
Maximum Continuous Output Current (per Phase)	24	36.25	40	48.25	Aac	
GFDI Threshold			1		Α	
Utility Monitoring, Islanding Protection, Country Configurable Set Points	Yes					
Total Harmonic Distortion	≤ 3			%		
Power Factor Range	+/- 0.85 to 1					
INPUT						
Maximum DC Power (Module STC)	27000	45000	50000	60000	W	
Transformer-less, Ungrounded			Yes			
Maximum Input Voltage DC+ to DC-	1000				Vdc	
Nominal Input Voltage DC+ to DC-			850		Vdc	
Maximum Input Current	26.5	36.25	40	48.25	Adc	
Maximum Input Short Circuit Current	33	55			Adc	
Reverse-Polarity Protection	Yes					
Ground-Fault Isolation Detection	1MΩ Sensitivity	167kΩ Sensitivity ⁽³⁾				
CEC Weighted Efficiency	98	98.5			%	
Night-time Power Consumption	<3	<4			W	
ADDITIONAL FEATURES						
Supported Communication Interfaces		2 x RS485, Etherno	et, Cellular (optional)			
Inverter Commissioning	With the SetApp mobile application using built-in access point for local connection					
Arc Fault Protection	Integrated, User Configurable (According to UL1699B)					
Rapid Shutdown	NEC2014, NEC2017 and NEC2020 compliant/certified					
RS485 Surge Protection Plug-in	Supplied with the inverter, Built-in					
DC Surge Protection	Type II, field replaceable, optional	Type II, field replaceable, Built-in				
AC Surge Protection	-	Type II, field replaceable, Built-in				
DC Fuses (Single Pole)	-	25A, Built-in				
Smart Energy Management	Export Limitation					
DC SAFETY SWITCH						
DC Disconnect		Inte	grated			
STANDARD COMPLIANCE	1					
Safety	UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to T.I.L. M-07					
Grid Connection Standards	IEEE1547, Rule 21, Rule 14 (HI)					
Emissions	FCC part15 class A					
INSTALLATION SPECIFICATIONS		·				
AC output conduit size / AWG range	3/4" minimum / 12-6 AWG		³ / ₄ " or 1" / 6 - 10 AWG			
DC input conduit size / AWG range		3/4" or 1" / 6 - 12 AWG				
Number of DC inputs pairs	2 4					
Dimensions with Safety Switch (H x W x D)	30.5 x 12.5 x 10.5 / 775 x 315 x 260	31.8 x 12.5 x 11.8 / 808 x 317 x 300		in / mm		
Weight with Safety Switch	74.2 / 33.7		78.2 / 35.5		lb / kg	
	Fans (user replaceable)					
Cooling		rans (user	replaceable)	< 50 < 62		
	< 50	rans (user			dBA	
Cooling	< 50					
Cooling Noise	< 50	-40 to +140	< 62		dBA °F/°C	

⁽¹⁾ For 120/208V inverters refer to: https://www.solaredge.com/sites/default/files/se-three-phase-us-inverter-208V-setapp-datasheet.pdf (2) For other regional settings please contact SolarEdge support (3) Where permitted by local regulations

⁽⁴⁾ For power de-rating information refer to: https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf