

Company Name: Lithion Battery Inc.
Address: Suite 100, 130 Cassia Way,
Henderson, NV 89014, USA

Email: sgraham@lithionbattery.com

**Subject:UL9540A Unit Level Testing to Battery System, Model Stack'd Series
(Project 80104654)**

Dear Mr Stewart Graham,

We hereby confirmed that we have finished testing of your battery system unit, model Stack'd Series based on the installation configuration: indoor floor mounted residential/non-residential applications in accordance with the requirement of UL 9540A 4th edition, section 9. During the test, cell to cell thermal runaway propagation was created, no propagation between units and no fire was observed. Test report will be issued shortly.

The product was evaluated to the applicable requirements:

ANSI/CAN/UL-9540A:2019 Test Method for Evaluating Thermal Runaway Fire Propagation
in Battery Energy Storage Systems, 4th edition.

Feel free to contact me or any of our Customer Service Representatives if you have any questions.

Thanks & Best regards,

Joseph Zhou



Certifier - CSA Group